

SPECIFICATION DATA



TRAMCO *Series 3100*

Industrial Sewage Pump

TRAMCO's *Series 3100* Vertical Sewage Pumps are engineered and precision built for years of dependable service. Quality materials and construction, together with a mechanical shaft seal design, allow continuous operation in liquids with abrasives and unscreened solids.

Applications

Sewage Lift Stations
Industrial Processes
Waste Treatment Plants
Underpass Drainage

Pump

The Series 3100 is a centrifugal type pump fitted with an enclosed impeller accurately machined and balanced for smooth, quiet operation. Capable of passing up to 3" diameter solids.

Mechanical Shaft Seal

Series 3100 pumps are fitted with a mechanical shaft seal which prevents the liquid being pumped from entering and contaminating the lower sleeve bearing while retaining the lubrication in the pump. Seals are available with hardened faces for abrasive liquid application.

Pump Lubrication

Tramco's lubrication system provides continuous lubrication to shaft, self lubricated intermediate and lower sleeve bearings. It eliminates the need for external grease lines or product lubricated sleeve bearings.

Shaft Column Pipe

The pump is manufactured with schedule 80 hot dipped galvanized steel.

Shaft

Size 1-1/4" high accuracy, grade 1215 turned, ground and polished. Shafts also available in stainless steel.

Discharge Pipe

Size 3", 4" or 6" schedule 40 hot dipped galvanized steel.

Motor Support Bracket

The heavy cast iron pedestal is accurately machined to house the thrust bearing and align the motor.

Thrust Bearing

The thrust ball bearing is grease lubricated and elevated above the cover plate for protection from dirt and moisture.

Floor Plate Suspension Cover

Heavy duty 20" diameter steel. Tramco will fabricate covers to duplicate existing pumps and piping.

Motors


The motor and pump shafts are connected by a flexible coupling that allows the motor to be easily removed without distributing the pump and piping.

Float Control (Optional)

Heavy duty pedestal mounted float switch is available with stainless steel float ball.

Basin Cover (Optional)

Heavy duty basin cover capable of supporting vertical suspended pumps and motors. Covers are available for simplex, duplex or other configurations.



QUALITY YOU CAN COUNT ON,
A NAME YOU CAN TRUST


Since 1924

TRAMCO PUMP COMPANY

1500 West Adams Street Chicago, Illinois 60607

Phone 312-243-5800 Fax 312-243-0702 Visit our Web Site at TRAMCOPUMP.COM

TRAMCO Series 3100 Sewage Pumps



Typical Specifications for a Duplex Vertical Sewage Pump System

Contractor shall furnish and install as shown on the plans a duplex Vertical sewage ejector pump system as designed and manufactured by Tramco Pump Company of Chicago, Illinois. The sewage ejector pump system shall consist of Two Tramco Vertical sewage ejector pumps and motors, a mechanical alternator assembly, emergency float switch and HWA assembly, duplex control panel, basin and basin cover.

Pumps: Furnish a duplex set of Tramco 3100 series vertical pumps each rated to deliver _____ GPM at _____ TDH. The pumps shall have heavy duty cast iron casings, enclosed type balanced cast iron impellers, grade 1215 turned, ground and polished shafting, raised upper grease lubricated ball thrust bearings. The pump shall be furnished with a 3" - 6" NPT schedule 40 galvanized discharge pipe and steel pump plate. The pump shall be fabricated with Schedule 80 galvanized shaft column constructed with an oil lubricated design having self lubricated intermediate and lower sleeve bearing(s), type 21 buna-N, Carbon vs. Ceramic mechanical shaft seal to prevent contamination of the lower sleeve bearing while providing continuous lubrication for the shaft. Pumps using product lubrication or grease lubricated bearings shall not be considered equal. Pumps using lip seals in lieu of a mechanical seal shall not be approved. Pumps using material other than galvanized steel of the above mentioned schedules, shall not be approved.

Motors: The motors shall be _____ HP, _____ RPM, _____ VOLT, _____ PHASE, _____ HZ, Totally enclosed fan cooled enclosure connected to the pump by use of a Woods style coupling assembly.

Control panel: Furnish for wall mounting a U.L. labeled Nema-_____ Duplex control panel with through the door main disconnect switch. Furnish for each pump a full voltage magnetic starter with properly size 3 leg overload protection, fuse block with fuses, Hand-Off-Auto selector switch, pump running light, a high water alarm horn, light and silence button and a control transformer for 115 volt control circuit. The control panel shall be factory internally prewired and tested in accordance with the provisions of the national electric code. All control wires shall be individually numbered and each component shall be labeled accordingly. All internal wiring shall be copper stranded, A.W.G., with a minimum insulation of 90° C. The complete assembly shall have a U.L. listing mark for industrial control panel and the enclosure. The enclosure shall be finished inside and out with a machinery grade enamel. The control panel shall include a terminal strip for connection of float control wiring as required for proper installation. All control wiring shall be neatly tucked inside wire raceways.

Float Controls: Furnish a Nema-_____ combination mechanical alternating float switch assembly with stainless steel float ball, solid brass float rod and float stops. The assembly shall consist of a pedestal base for basin cover mounting. Furnish a Nema-emergency float switch assembly with stainless steel float ball, solid brass float rod and float stops for activation of the pump and high water alarm if the alternator or first pump fails. The assembly shall consist of a pedestal base for basin cover mounting.

Basin Cover: Furnish a duplex steel basin cover _____ Dia. including all necessary openings for pumps, vent, inspection cover and float assemblies. The basin cover shall be _____ " thick steel plate and shall be painted with a corrosion resistant paint.

TRAMCO PUMP COMPANY

1500 West Adams Street Chicago, Illinois 60607
Phone 312-243-5800 Fax 312-243-0702